

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHEISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1230213

**Product:** Lightning conductors and grounding system's parts- air-termination rods, insertion rods, earthing rods and plates

**Type:** see Annex

**Rating:** air-termination -  $\varnothing$  18, earthing rod -  $\varnothing$  25, 50x50x3, 2000x250, 1000x500,  $\varnothing$  18

**Ordering firm:** TREMIS s.r.o.  
č.p.28, 410 02 Lukavec, Czech Republic

**Manufacturer:** TREMIS s.r.o.  
č.p.28, 410 02 Lukavec, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 231039-01/01 of: 18.05.2023

**A sample of the product was found to be in conformity with:**  
ČSN EN IEC 62561-2 ed.2:18 cl. 4.3, 4.5, 5.2.5, 5.2.6

**Other data:**

**The validity of the certificate is limited to:** 22.05.2026

23.05.2023

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



231039-01